


**Site: Kai Stafford**
**Location: SL7 1TS**

Asset ID: 001	Description: ADJ Moving Head	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	------------------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 002	Description: ADJ Moving Head	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	------------------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 003	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
<b>Overall: Pass</b>				



IEC Lead Continuity	08/03/2022	0.05	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 004	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.05	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 005	Description: Warlock	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 006	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Plug	08/03/2022			Pass
<b>Overall: Pass</b>				



Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.06	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 007	Description: Numark M6	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 008	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.13	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				



Asset ID: 009	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.11	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 010	Description: PSU	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 011	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
<b>Overall: Pass</b>				



IEC Lead Continuity	08/03/2022	0.08	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 012	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.08	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 013	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.07	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 014	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	------------------	----------------	---

Comments:



Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.07	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass

Overall: Pass

Asset ID: 015	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.16	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass

Overall: Pass

Asset ID: 016	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.04	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass

Overall: Pass



Asset ID: 017	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.05	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 018	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.07	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 019	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
<b>Overall: Pass</b>				



Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.03	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 020	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.06	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 021	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.07	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 022	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				





Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.06	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass

Overall: Pass

Asset ID: 023	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.05	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass

Overall: Pass

Asset ID: 024	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.1	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass

Overall: Pass



Asset ID: 025	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.1	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 026	Description: 4 Way Extension	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.13	ohm	Pass
IEC Lead Continuity	08/03/2022	0.13	ohm	Pass
IEC Lead Continuity	08/03/2022	0.13	ohm	Pass
IEC Lead Continuity	08/03/2022	0.13	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
<b>Overall: Pass</b>				

Asset ID: 027	Description: 4 Way Extension	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
<b>Overall: Pass</b>				



Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.14	ohm	Pass
IEC Lead Continuity	08/03/2022	0.14	ohm	Pass
IEC Lead Continuity	08/03/2022	0.16	ohm	Pass
IEC Lead Continuity	08/03/2022	0.15	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass

Overall: Pass

Asset ID: 028	Description: PSU	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 029	Description: PSU	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass

Overall: Pass



Asset ID: 030	Description: Pioneer XDJ RX3	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 031	Description: IEC	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
IEC Lead Continuity	08/03/2022	0.06	ohm	Pass
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
IEC Lead Polarity	08/03/2022			Pass
				Overall: Pass

Asset ID: 032	Description: Speaker	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
				Overall: Pass



Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 033	Description: RCF Speaker	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 034	Description: RCF Speaker	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 035	Description: PSU NEON1E	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
				Overall: Pass



Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 036	Description: PSU NEON2BIY	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 037	Description: PSU NEON3TD	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 038	Description: PSU NEON4DIL	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
<b>Overall: Pass</b>				



Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 039	Description: PSU NEON5MAM	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 040	Description: PSU NEON6TD	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 041	Description: PSU NEON7HEA	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
<b>Test Type</b>	<b>Date</b>	<b>Result</b>	<b>Unit</b>	<b>Status</b>
Plug	08/03/2022			Pass
<b>Overall: Pass</b>				



Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 042	Description: PSU NEON8LM	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 043	Description: PSU NEON09WTW	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				
Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 044	Description: PSU NEON10SIB	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173	
Comments:				





Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 045	Description: PSU NEON11LR	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	---------------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 046	Description: PSU NEON12IW	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	---------------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 047	Description: PSU NEON13CIL	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	----------------------------	----------------	---

Comments:



Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 048	Description: PSU NEON14FAA	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	----------------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 049	Description: PSU NEON15BT	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	---------------------------	----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
<b>Overall: Pass</b>				

Asset ID: 050	Description: PSU	User: JKipping	Test Instrument: Seaward Apollo 600 Plus 51M-1173
---------------	------------------	----------------	---

Comments:



Test Type	Date	Result	Unit	Status
Plug	08/03/2022			Pass
Flex	08/03/2022			Pass
Enclosure	08/03/2022			Pass
Environment	08/03/2022			Pass
Socket	08/03/2022			Pass
Switch	08/03/2022			Pass
Voltage	08/03/2022	230	V	Information
Insulation Voltage	08/03/2022	500	V	Information
Insulation	08/03/2022	> 19.99	MOhm	Pass
				Overall: Pass

Total Tests: 50