

# PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

Certificate Reference: KS/SM/24 / Test Equipment used Martindale EPAT1600 Dual Voltage Manual PAT Tester /  
Serial Number B12789H6 Tested by - Supersonic Group (PAT)  
Test Date - 05/01/26 / Retest Date 05/01/27

	Make/Model	Voltage (V)	Rating (A)	Fuse Rating	Insulation resistance	Earth continuity	Load	Plug, flex & body OK?	OK
Item - 1	IEC LEAD	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 2	IEC LEAD	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 3	IEC LEAD	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 4	IEC LEAD	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 5	IEC LEAD	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 6	IEC LEAD	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 7	IEC LEAD	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 8	IEC LEAD	230	13		PASS	PASS	PASS	OK	PASS
Item - 9	RCF J8 SPEAKER	230	13	13	PASS	CLASS 2	PASS	OK	PASS
Item - 10	RCF J8 SPEAKER	230	13	13	PASS	CLASS 2	PASS	OK	PASS
Item - 11	ADJ MOVING HEAD LIGHT	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 12	ADJ MOVING HEAD LIGHT	230	13	13	PASS	PASS	PASS	OK	PASS

# PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

Certificate Reference: KS/SM/24 / Test Equipment used Martindale EPAT1600 Dual Voltage Manual PAT Tester /  
Serial Number B12789H6 Tested by - Supersonic Group (PAT)  
Test Date - 05/01/26 / Retest Date 05/01/27

	Make/Model	Voltage (V)	Rating (A)	Fuse Rating	Insulation resistance	Earth continuity	Load	Plug, flex & body OK?	OK
Item - 13	IBIZA POWERED SPEAKER	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 14	EQUINOX STARCLOTH CONTROL	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 15	NUMARK MIXER	230	13	13	PASS	CLASS 2	PASS	OK	PASS
Item - 16	POWERCON LEAD	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 17	POWERCON LEAD	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 18	POWERCON LEAD	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 19	POWERCON LEAD	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 20	RCF J8 SPEAKER	230	13	13	PASS	CLASS 2	PASS	OK	PASS
Item - 21	RCF J8 SPEAKER	230	13	13	PASS	CLASS 2	PASS	OK	PASS
Item - 22	IEC LEAD	230	13	13	PASS	PASS	PASS	OK	PASS

# PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

Certificate Reference: KS/SM/24 / Test Equipment used Martindale EPAT1600 Dual Voltage Manual PAT Tester /  
Serial Number B12789H6 Tested by - Supersonic Group (PAT)  
Test Date - 05/01/26 / Retest Date 05/01/27

	Make/Model	Voltage (V)	Rating (A)	Fuse Rating	Insulation resistance	Earth continuity	Load	Plug, flex & body OK?	OK
Item - 23	IEC LEAD	230	13	13	PASS	PASS	PASS	OK	PASS
Item - 24	AD/DC ADAPTER	230	13	13	PASS	CLASS 2	PASS	OK	PASS
Item - 25	AD/DC ADAPTER	230	13	13	PASS	CLASS 2	PASS	OK	PASS
Item - 26	AD/DC ADAPTER	230	13	13	PASS	CLASS 2	PASS	OK	PASS
Item - 27	4ft LETTER - L	230	13	13	PASS	CLASS 2	PASS	OK	PASS
Item - 28	4ft LETTER - O	230	13	13	PASS	CLASS 2	PASS	OK	PASS
Item - 29	4ft LETTER - V	230	13	13	PASS	CLASS 2	PASS	OK	PASS
Item - 30	4ft LETTER - E	230	13	13	PASS	CLASS 2	PASS	OK	PASS